



Huguley Water, Sewer, and Fire Protection Authority

P.O. Box 426
Lanett, AL 36863

OFFICE: (334) 576-8113
Fax: (334) 576-7187

Huguley, Water, Sewer, and Fire Protection Authority Lead Service Line Inventory

Pursuant to the requirements of the Lead and Copper Rule, Huguley Water, Sewer, and Fire Protection Authority conducted an inventory of all service lines within our water system. Based upon the inventory, it was determined that Huguley Water, Sewer, and Fire Protection Authority has no lead service lines (LSLs), no galvanized requiring replacement (GRRs), and no lead status unknown service lines within the water system.

Definitions:

Galvanized requiring replacement (GRRs) – galvanized service line that is currently downstream of a lead service, has previously been downstream of a lead service line, or is currently downstream of a “Lead Status Unknown” service line.

Lead Service Line (LSLs) – Service line made of lead.

Lead Status Unknown – Service line material is not known to be lead, galvanized requiring replacement, or a non-lead service line, such as where there is no documented evidence supporting material classification.

Service Line – Pipe used in a potable water distribution system that connects a water main to the user’s premises. For the purpose of this inventory, the service line is considered the pipe from the watermain to the home.

Methodology

Huguley Water, Sewer, and Fire Protection Authority has a total of 2,539 active and inactive water services. Huguley Water, Sewer, and Fire Protection Authority used the following methods to determine the lead status of the services:

Installation date after the lead ban – The federal lead ban took effect June 19, 1986. The ban required that only lead-free pipe, solder, or flux may be used in the installation or repair of public water systems or any residential or non-residential facility providing water for human consumption.

Field Verified – Huguley Water, Sewer, and Fire Protection Authority personnel verified **ALL** services by performing an onsite field investigation.

This survey was conducted to meet the requirements of the Environmental Protection Agency (EPA) Lead and Copper Rule (LCRR), as implemented by the Alabama Department of Environmental Management (ADEM). The EPA Lead and Copper Rule regulations seek to identify and eliminate sources of lead in older drinking water service lines. Service Line Inventory was completed and submitted to ADEM on September 10, 2024.